



CONSTRUCTION NOTES

- #1 TO #4 NOT-IN-USE
- 5 TILE FLOOR
- 6 HARDWOOD FLOOR
- 7 TYP "X" GYP. BD. WALLS & CEILINGS
- 8 WOOD TREADS & RISERS
- 9 WROUGHT IRON GURADRAIL (42" MIN)
PROVIDE 42" HIGH GURAD WITH MAX 4" CLEAR
SPACING OPENING BETWEEN RAILS
- 10 ATTIC ACCESS - MIN 20" X 30"
- 11 TEMP. GLZ SHOWER DOOR & ENCLOSURE
- 12 SCUPPER & OVERFLOW
- 13 MER-KO WEATHER DECK - LA.RR. 23811

- EXHAUST FAN
- SD SMOKE DETECTOR

- NOTES:
- ENCLOSED USEABLE SPACE UNDER INTERIOR
STAIR REQUIRES ONE-HOUR FIRE RESISTIVE
CONSTRUCTION ON ENCLOSED SIDE.
 - PROVIDE 70" HIGH NON-ABSORBENT WALL
ADJACENT TO SHOWER AND APPROVED
SHATTER-RESISTANT MATERIALS FOR SHOWER ENCLOSURES.
 - ALL INTERIOR AND EXTERIOR STAIRWAYS SHALL BE ILLUMINATED
 - BATHROOMS, WATER CLOSET COMPARTMENTS AND OTHER
SIMILAR ROOMS SHALL BE PROVIDED NATURAL VENTILATION
OR WITH MECHANICAL VENTILATION CAPABLE OF 50 cfm
EXHAUSTED DIRECTLY TO THE OUTSIDE
 - HEATER SHALL BE CAPABLE OF MAINTAINING A MINIMUM
ROOM TEMPERATURE OF 68° F AT THE POINT 3 FEET ABOVE
THE FLOOR AND 2 FEET FROM EXTERIOR WALLS IN ALL HABITABLE
ROOMS AT THE DESIGN TEMPERATURE

PROPOSED FIRST FLR PLN
1/4" = 1'-0"

- EXISTING WALL TO REMAIN
- PROPOSED 2 x 4 WALL
- PROPOSED 2 x 6 WALL

NOTE: ALL DIMENSIONS TO WALL UNLESS NOTED OTHERWISE