


NOTE: ATTIC VENTILATION OF 1/150 OF AREA VENTILATED (APROX.  
10SQ.INCH FOR EACH 10 SQ.FT. OF ATTIC AREA) IS REQUIRED  
 $\frac{1,949 \text{ SQ.FT.}}{150} = 13 \text{ SQ.FT. OF REQUIRED VENT}$   
TOTAL VENTS REQUIRED = 11 VENTS HIGH & 11 VENTS LOW BY  
O'HAGGING'S INC. LA, R.R. 25497



PROPOSED ROOF FLR PLN  
1/4"=1'-0"

PROPOSED ROOF PLAN

DATE: 10/12/11

SCALE: 1/4"=1'-0"